



RUSSELLVILLE FIRE DEPARTMENT
POLICY MANUAL

Policy Number:
Section:
Original Date:
Revised Date:

PURPOSE

To define intervals at which RFD equipment must be tested and/or periodic maintenance be performed.

POLICY

RFD Administration keeps records on all equipment, from the date of purchase, to each repair made. The Fire Chief shall advise each Shift Commander of the equipment to be tested by each shift that year or proper interval. Each Shift Commander shall ensure that records are properly filed.

Equipment shall be tested and/or maintained at the following intervals:

Equipment	Interval	SOP
Pump Test	Annual	208.14
Flushing Pumps/Maint	Monthly	208.15
Hose Test	Annual	208.11
Storz Intake	Monthly	208.12
Ladder Maintenance	Monthly	208.06
Hose Load Rotation	6 Months	208.13
Small Equipment	Semi-Annual	208.09
SCBA	Annual	206.05

Approved

Fire Chief